

## TYPE EXAMINATION CERTIFICATE

**No. 17-0449**

**Certificate issued by Notified Body N° 1611**

1. Product name: PVC Flooring
2. Product material: Raw material: PVC Resin, Plasticizer (DOTP), calcium zinc stabilizer, calcium carbonate, carbon black
3. Product type:
  - a. thickness: 1.5 mm - 5.0 mm
  - b. density: 1900±50 kg/m<sup>3</sup>
4. Numerical code of product classification:
  - a. fire behaviour: **B fl s1**
  - b. formaldehyde: **E1**
  - c. slip resistance: **DS**
5. Usage of the product: HOME, OFFICES, BOUTIQUES, CONFERENCE ROOMS, SALES ROOMS, SCHOOLS AND KINDERGARTENS, KITCHENS, PRIVATE AND COMMERCIAL ARREARS WITH INTENSIVE USE.
6. Manufacturer: JIANGSU DONGZHENG NEW DECORATION MATERIALS CO., LTD.
7. Address: HENGLIN TOWN, CHANGZHOU, JIANGSU, CHINA

This certificate assures the compliance of properties of the product, which complies with the technical requirements referenced in EN 14041, EN 13501-1, EN 717-1 and EN 13893. The certificate only applies to materials that correspond to the tested sample.


The results of tests and findings on conformity of the properties of the given type with technical requirements are referenced in classification report CR-17-0449/01, Test Reports 17-0449-01, 17-0449-02, 17-0449-03 and MVZ-A-2017-000076.

**Date of issuing: 9/05/2017**

**Valid until: 2022**

*The Centre for Textile Science and Engineering of Ghent University (Belgium) is recognized as notified laboratory N° 1611 for the European regulation 305/2011 for construction products.*

Didier Van Daele  
Head of floorcovering/fire tests



Prof. Dr. Paul KIEKENS, dr. h. c.  
Director